•
Α

Reg. No.:										
-----------	--	--	--	--	--	--	--	--	--	--

# **Question Paper Code: 57302**

#### B.E./B.Tech. DEGREE EXAMINATION, NOV 2018

#### Seventh Semester

## Electrical and Electronics Engineering

### 15UEE702 – POWER SYSTEM OPERATION AND CONTROL

(Regulation 2015)

Duration: Three hours

Maximum: 100 Marks

**Answer ALL Questions** 

PART A -  $(10 \times 1 = 10 \text{ Marks})$ 

1. Which of the following represents the annual average load?

CO1-R

- (a) (KWh supplied in a day)/24
- (b){(KWh supplied in a day)/ 24 }  $\times$  365
- (c)  $\{(KWh \text{ supplied in a month})/(30 \times 24)\}$
- (d) (KWh supplied in a year) / (24  $\times$  365)
- 2. What happens to frequency if the load on the generator increases?

CO1-R

- (a) Speed increases and frequency decreases
- (b) Speed decreases and frequency decreases
- (c) Speed increases and frequency increases
- (d) Speed decreases and frequency increases
- 3. Unit of Load damping constant *B* is

CO2-R

- (a) MVAr/Hz
- (b) MVA/Hz
- (c) MW/Hz
- (d) MW-s


4. Area of frequency response characteristic ' $\beta$ ' is

CO2- R

- (a) 1/R
- (b)*B*

- (c)B + 1/R
- (d)B 1/R

5. This model may named as



CO3-R

- (a) Comparator
- (b) Amplifier
- (c) Exciter
- (d) Synchronous Generator

- 6. For synchronous condensers, the p.f. improvement apparatus should be located at
  - (a) Sending end (b) Receiving end (c) Both (a) and (b) (d) None of these
- 7. Unit of  $\lambda$  is CO4- R
  - (a) Rs./hr (b)Rs./MW (c) Rs./MWh (d) MW/Rs
- 8. The equality constraint, when the transmission line losses are considered, is
  - (a)  $\sum_{i=1}^{n} P_{G_{i}} P_{L} = 0$ . (b)  $\sum_{i=1}^{n} P_{G_{i}} - P_{D} = P_{L} + P_{G}$ . (c)  $\sum_{i=1}^{n} P_{G_{i}} - P_{D} = 0$ . (d)  $\sum_{i=1}^{n} P_{G_{i}} - P_{L} = P_{D}$ .
- 9. State estimation scheme uses CO5- R
  - (a) Lagrangian function method(b) Negative gradient method(c) Lyapunov method(d) Weighted least square method
- 10. Security control system is a system of CO5- R
  - (a) Manual control (b) Integrated automatic control
    - (c) Conventional generation control (d) Both (a) and (b)

## PART - B (5 x 2= 10Marks)

- 11. What is Load factor?
- 12. What is meant by control area?
- 13. What is meant by stability compensation? CO3- R
- 14. Comparison between unit commitment and economic dispatch CO4 -R
- 15. What is Energy Management System? What are the major functions of it? CO5- R

$$PART - C (5 \times 16 = 80 Marks)$$

16. (a) A generating station has the following daily load curve CO1-App (16)

Time (hours)	0-6	6-10	10-12	12-16	16-20	20-24
Load (MW)	40	50	60	50	70	40

Draw the load curve, load duration curve and compute the maximum demand and Evaluate the units generated per day, average load and load factor for the above problem.

(b) (i) Calculate the diversity factor and the annual load factor of a CO1- App generating station, which supplies the following loads to various consumers:

Industrial consumers – 2000kW

Commercial load-1000kW

Domestic load- 200kW

Domestic light- 500kW

If the maximum demand on the station is 3000 kW, and the number of units produced per year is  $50*10^5$ .

(ii) Explain about plant level and system level controls.

CO1- U

(8)

17. (a) A two area power system has two identical areas ,consider the CO2-App (16) following data:

Area capacity = 1500MW

Nominal operating load = 750 MW

Inertia constant = 5 sec

Speed Regulation of all regulating generators = 3 %

Frequency = 50 Hz

Damping coefficient = 1%

Governor time constant = 0.06 sec

Turbine time constant = 0.25 sec

A load increases  $M_1 = 30MW$  occurs in area 1.

Determine (i)  $\Delta f_{\text{stat}}$  and  $\Delta P_{12\text{stat}}$ .

Or

- (b) Develop a transfer function of the speed governing mechanism CO2-App (16) and sketch a block diagram. What are the components of speed governor system of an alternator? Explain in detail.
- 18. (a) Draw the diagram of typical Automatic Voltage Regulator and CO3- Ana (16) develop Modeling of Automatic Voltage Regulator its block diagram representation.

Or

- (b) (i) Derive the relations between voltage, power and reactive CO3- Ana power at a node for applications in power system control.
  - (ii) Discuss in detail about the generation and absorption of CO3-Ana (8) reactive power

- 19. (a) (i) Explain how the forward dynamic programming solution is CO4 -U (8) applied in unit's commitment problem describe by using flow chart.
  - (ii) Illustrate the  $\lambda$  iteration method for finding the solution of CO4 -U (8) economic dispatch without transmission losses with a neat flow chart.

Or

(b) (i) Analyze priority list using full load average production for the CO4-Ana (10) data given below.

Unit	Loading		Fuel co	st para	Fuel cost	
No	limits					
	Min		$a_{i}$	$b_i$	$c_{i}$	
	Max					
1	100	400	0.006	7	600	1.1
2	50	300	0.01	8	400	1.2
3	150	500	0.008	6	500	1.0

 $P_{D} = 800MW.$ 

(ii) Explain about the thermal unit constraints.

CO4-U

(6)

20. (a) Enumerate the various operating states and the control strategies CO5-U (16) of a power system.

Or

(b) Illustrate the different function that are performed by the CO5-U (16) SCADA system.